



Government Of West Bengal
Office Of The Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.- Bengal Enamel, Pin :- 743122

Memo no.:IND/WB/FES/20192020/84977

Date: 22-12-2021

From:

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

To: Mahendra Memorial School

Sindrani, P.S. - Bagdah, North 24 Parganas, Pin - 743292

Sub: Fire Safety Certificate for an existing G+III storied building under group Educational of M/S MAHENDRA MEMORIAL SCHOOL at the premises VILL- SINDRANI, P.O.- SINDRANI, P.S.- BAGDAH, District- North 24 Parganas, PIN- 743292 West Bengal

This is in reference to your application no. 0125189211100402 dated 04-12-2021 regarding the Fire Safety Certificate for an existing G+III storied building under group Educational of M/S MAHENDRA MEMORIAL SCHOOL at the premises VILL- SINDRANI, P.O.- SINDRANI, P.S.- BAGDAH, District- North 24 Parganas, PIN- 743292 West Bengal


The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.


Recommendation:


1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a closed circuit T.V system will have to be installed which observe all floor of the buildings.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189211100402.

Page : 1


Manager
MAHENDRA MEMORIAL SCHOOL
Vill+P.O-Sindrani, 24 Pgs.(N)
PIN-743297

Powered By  For secure paperless solutions
Please visit www.emsigner.com



Principal
Mahendra Memorial School
Sindrani Bagdah N-24 Pgs, 743297

Building.

7. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
8. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Transformer and Switch Gear room shall be protected with automatic CO₂ or D.C.P. Fire extinction confirming I.S. Specification.
10. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
12. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical flashing of water in the Hydrants and Sprinkler Pipe line shall be made to maintain the efficiency working performance of above mention system.
14. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
15. The Head of the organization / Society as the case may be, shall submit a declaration to the Director General, West Bengal Fire & Emergency Services on every 1st April, 1st July, 1st October, & 1st January maintaining financial calendar that "The Fire Prevention and Fire Safety Measures in the building or premises have been tested and are in good working condition. That, no material changes has been done in the building that has affected the means of escape and means of access as the case may be. That, all the members of the organization are well conversant with the evacuation drill and mentally & physically fit to combat the Fire Emergencies. That, any deviation in the above and failure in maintenance of the Fire Prevention and fire safety measures shall at the risk and liability of the Head of the organization/ Society.


This certificate is valid for 3 years from the date of issue and renewable after three years is to be obtained from the Divisional Fire Officer, North 24 Parganas Division, West Bengal Fire & Emergency Services for performance of all the life & Fire Safety arrangements and installations of the building failing which this shall be revoked automatically.


Signature valid


Digitally signed by DEBTANU
BASU
Date: 2021.12.22 17:34:40 IST

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189211100402. Page : 2


Manager
MAHENDRA MEMORIAL SCHOOL
Vill+P.O-Sindrani, 24 Pgs.(N)
PIN-743297

Powered By  For secure paperless solutions
Please visit www.emsigner.com


Principal
Mahendra Memorial School
Sindrani, Bagdah, N-24 Pgs, 743297